

# WINDOW / DOOR INSTALLATIONS

PER FLORIDA BUILDING CODE 5<sup>TH</sup> EDITION (2014) ENERGY CONSERVATION- C402.3.3 AND R402.3.6

## ALL WINDOW/DOOR INSTALLATIONS MUST MEET THE REQUIREMENTS OF THE ENERGY CONSERVATION CODE

### U-FACTOR

RESIDENTIAL <b>NON-IMPACT</b> WINDOWS/DOORS WITH GLAZING	MUST BE EQUAL OR LESS THAN <b>.40</b>
RESIDENTIAL <b>IMPACT</b> WINDOWS/DOORS WITH GLAZING	MUST BE EQUAL OR LESS THAN <b>.65</b>
COMMERCIAL <b>FIXED</b> WINDOWS	MUST BE EQUAL OR LESS THAN <b>.50</b>
COMMERCIAL <b>OPERABLE</b> WINDOWS	MUST BE EQUAL OR LESS THAN <b>.65</b>
COMMERCIAL DOORS WITH GLAZING	MUST BE EQUAL OR LESS THAN <b>.83</b>

### SOLAR HEAT GAIN COEFFICIENT (SHGC)

COMMERCIAL AND RESIDENTIAL

WINDOWS/DOORS WITH GLAZING	MUST BE EQUAL OR LESS THEN <b>.25</b>
----------------------------	---------------------------------------

**A COPY OF THE ENERGY PERFORMANCE RATING STICKER FOR YOUR PRODUCTS– MUST BE SUBMITTED WITH YOUR PRODUCT APPROVALS AND THE ACTUAL STICKER/LABEL MUST BE ON SITE FOR INSPECTION.**

See below sample



HOW MANY STORIES \_\_\_\_\_ MULTI-FAMILY    no        yes   

I certify that the Energy Performance Rating Information submitted is for the product being installed and I accept full responsibility for the installation.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Print Name