

Duct Leakage Test Report

Residential Prescriptive, Performance or ERI Method Compliance
2017 Florida Building Code, Energy Conservation, 6th Edition

Jurisdiction: _____	Permit #: _____
---------------------	-----------------

Job Information

Builder: _____	Community: _____	Lot: _____
Address: _____	Unit: _____	
City: _____	State: _____	Zip: _____

Duct Leakage Test Results

System 1	_____ cfm25
System 2	_____ cfm25
System 3	_____ cfm25
Sum of any additional systems	_____ cfm25
Total of all systems	_____ cfm25

Prescriptive Method cfm25 (Total)
To qualify as "substantially leak free" Qn must be less than or equal to 0.04 if air handler unit is installed. If air handler unit is not installed, Qn Total must be less than or equal to 0.03. This testing method meets the requirements in accordance with Section R403.3.3.

Performance / ERI Method cfm25 (Out or Total)
To qualify using this method, Qn must not be greater than the proposed duct leakage Qn specified on Form R405-2017 or R406-2017.

Leakage Type selected on Form R405-2017 (Energy Calc) or R406-2017 *Qn specified on Form R405-2014 (Energy Calc) or 406-2017*

$$\frac{\text{Total of all systems}}{\text{Total Conditioned Square Footage}} = \text{_____ Qn}$$

PASS **FAIL**

Duct tightness shall be verified by testing in accordance with ANSI/RESNET/ICC380 by either individuals as defined in Section 553.993(5) or (7), Florida Statutes, or individuals licensed as set forth in Section 489.105(3)(f), (g) or (i), Florida Statutes.

Testing Company

Company Name: _____ Phone: _____

I hereby verify that the above duct leakage testing results are in accordance with the 2017 6th Edition Florida Building Code Energy Conservation requirements according to the compliance method selected above.

Signature of Tester: _____ Date of Test: _____

Printed Name of Tester: _____